

**CALITATEA APEI POTABILE**  
**MEDGIDIA**  
**Iunie 2017**

<b>NR. CRT.</b>	<b>PARAMETRU</b>	<b>LIMITE ADMISE Legea 458/2002 Legea 311/2004</b>	<b>ORAȘ MEDGIDIA</b>
<b>1</b>	Gust	<b>acceptabil</b>	acceptabil
<b>2</b>	Miros	<b>acceptabil</b>	acceptabil
<b>3</b>	Culoare, mg/l Pt-Co	<b>acceptabila</b>	acceptabila
<b>4</b>	Turbiditate, NTU	<b>&lt;5</b>	<0.630
<b>5</b>	pH, unit. pH	<b>6,5-9,5</b>	7.44
<b>6</b>	Amoniu, (NH <sub>4</sub> <sup>+</sup> ), mg/l	<b>0,5</b>	<0.054
<b>7</b>	Nitriti, (NO <sub>2</sub> <sup>-</sup> ), mg/l	<b>0,5</b>	<0.027
<b>8</b>	Clor rezidual liber, mg/l	<b>0,1÷0,5</b>	0.2
<b>9</b>	Indice permanganat, mg /l O <sub>2</sub>	<b>5</b>	<0.590
<b>10</b>	Duritate totala, °germ.	<b>&gt;5</b>	17.9
<b>11</b>	Conductivitate, μS/cm	<b>2500</b>	773
<b>12</b>	Bacterii coliforme, nr./100 ml	<b>0</b>	0
<b>13</b>	<i>E. Coli</i> , nr./100 ml	<b>0</b>	0
<b>14</b>	Enterococi, nr./100 ml	<b>0</b>	0

